

Addendum 002

Project Name: **P23-BLDG-07 (Building 100 HVAC)**

Bid Due Date: **01/03/2024 @ 9:00am**

ADDENDUM INFORMATION

This Addendum addresses the following changes/additions/deletions for the above referenced project:

ITEM	DESCRIPTION
1.	Windows will be framed in with wood and tin where units are located. Core drilling thru brick for PVC exhaust will NO longer be necessary. The PVC lines can be run thru the plywood and tin.
2	
3	
4	
5	

Revised documents can be obtained online at <https://www.americascentralport.com/planroom>.

A signed copy of this Addendum is to be included with the Bid Proposal indicating that Bidder has read and understood the modifications made to the Bidding Documents. Bidder shall also indicate this Addendum within Article 3.01.A of the 00410 - Bid Form.

BIDDER CERTIFICATION STATEMENT

I hereby attest that I have read and understood the changes listed in this Addendum for the above referenced Project and have submitted a Bid Proposal that reflects these changes.

Signature: _____

Date: _____