

Addendum 001

Project Name: **P23-BLDG-07 (Building 100 HVAC)**

Bid Due Date: **01/03/2024 @ 9:00am**

ADDENDUM INFORMATION

This Addendum addresses the following changes/additions/deletions for the above referenced project:

ITEM	DESCRIPTION
1	Electric disconnect and final reconnect will be done by ACP. (Contractor will come back for start-up)
2	Contractor to replace all the line sets. There are six sets of refrigeration lines that will be replaced. Each set will have a new liquid line dryers.
3	Contractor will supply drain trays under each unit. The contractor will supply six drain pans under the units to prevent water damage.
4	Contractor will be responsible for the purchase and complete installation of six twined new units.
5	

Revised documents can be obtained online at <https://www.americascentralport.com/planroom>.

A signed copy of this Addendum is to be included with the Bid Proposal indicating that Bidder has read and understood the modifications made to the Bidding Documents. Bidder shall also indicate this Addendum within Article 3.01.A of the 00410 - Bid Form.

BIDDER CERTIFICATION STATEMENT

I hereby attest that I have read and understood the changes listed in this Addendum for the above referenced Project and have submitted a Bid Proposal that reflects these changes.

Signature: _____

Date: _____