

Addendum 003

Project Name: **P23-BLDG-07 (Building 100 HVAC)**

Bid Due Date: **01/04/2024 @ 9:00am**

ADDENDUM INFORMATION

This Addendum addresses the following changes/additions/deletions for the above referenced project:

ITEM	DESCRIPTION
1	Contractor responsible for removing 6 AC Units. (ACP will haul away) Contractor will install six 10-ton 2 stage units. 410A-3ph 208v
2	Contractor to install low ambient controls to outside AC units and hail guards. Contractor is responsible for removing all freon from units.
3	Bid due date is now 1/4/2024 at 9am.
4	
5	

Revised documents can be obtained online at <https://www.americascentralport.com/planroom>.

A signed copy of this Addendum is to be included with the Bid Proposal indicating that Bidder has read and understood the modifications made to the Bidding Documents. Bidder shall also indicate this Addendum within Article 3.01.A of the 00410 - Bid Form.

BIDDER CERTIFICATION STATEMENT

I hereby attest that I have read and understood the changes listed in this Addendum for the above referenced Project and have submitted a Bid Proposal that reflects these changes.

Signature: _____

Date: _____